



EXISTING STANDARD PROPERTIES WARE

CONCRETE FLUME

24" DRAFT CURTAIN

24" DRAFT CURTAIN

MUST DELIVER 800 GPM @ 25 PSI AT THIS POINT

CHECK VALVES MAY BE REQUIRED

NOTES AND SYMBOLS
 FOREMAN TO LOCATE HIGH DEGREE HEAD IN FIELD.
 PITCH OF PIPING FOR DRAINAGE AND LOCATION OF HANGERS TO BE AS PER N.F.P.A. #13 - LATEST EDITION FOREMAN TO LOCATE W/M GONG IN FIELD.
 ○ DENOTES UPRIGHT SPRK HEAD
 ⊕ DENOTES SIDEWALL SPRK HEAD NIPPED UNDER OVERHEAD DOOR
 [] DENOTES CENTER LINE OF PIPING BELOW TOP OF STEEL - THESE DIMENSIONS ARE SUBJECT TO CHANGE DUE TO FIELD CONDITIONS

1. SPRINKLERS MUST BE 1 1/32" DRIFICE (3/4" OUTLETS)
2. REARRANGE SPRINKLERS AROUND DRAFT CURTAINS WHERE NECESSARY
3. WATER MUST REACH INSPECTORS TEST WITHIN 60 SEC.

SPRINKLER LAYOUT
 SCALE 1/8" = 1'-0"

MARYLAND FIRE UNDERWRITERS RATING BUREAU
 LAYOUT APPROVED
 BASED ONLY UPON INFORMATION CONTAINED ON THIS PLAN
 DATE APR 14 1971 BY *E.J. Safferty*

WAREHOUSE No. 3-B
 HYATTSVILLE INDUSTRIAL
 EDMONSTON
 PRINCE GEORGES COUNTY, MARYLAND
 TYPE OF SYSTEM
 DRY-Mod. Ex Haz - 90 So. Ft. Spacing
 AREA
 WHSE 3B - UNITS 1-2-3 AND 4 300/300
 SCALE 1/8" = 1'-0" DATE 4-6-71 DRAWN BY J.E.L. SHEET NO. 1 OF 2
 SUPERVISING AUTHORITY
 M.F.U.R.B. AND PR. GEO. COUNTY F.M. 644
 CONTRACTOR
 MARTIN BROS., INC.
 VIRGINIA SPRINKLER CO., INC.
 P. O. DRAWER 5191
 ASHLAND VIRGINIA

SUBJECT TO A STANDARD WATER SUPPLY OF ADEQUATE VOLUME & PRESSURE.